

White Tank FRS #4								
-------------------	--	--	--	--	--	--	--	--

Discharge Rating Table - table values in CFS						
--	--	--	--	--	--	--

Rating assumes gated outlets are open and ungated outlet is open as of March 2021.		
--	--	--

[illegible]

White Tank FRS #4										
Discharge Rating Table - table values in CFS										
Rating assumes gated outlets are open and ungated outlet is open as of March 2021.										
	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
3.5	42	42	42	42	42	42	42	42	42	43
3.6	43	43	43	43	43	43	43	43	44	44
3.7	44	44	44	44	44	44	44	44	45	45
3.8	45	45	45	45	45	45	45	46	46	46
3.9	46	46	46	46	46	46	47	47	47	47
4.0	47	47	47	47	47	47	47	47	47	47
4.1	47	47	48	48	48	48	48	48	48	48
4.2	48	48	48	48	48	48	48	48	48	48
4.3	48	48	48	48	48	48	49	49	49	49
4.4	49	49	49	49	49	49	49	49	49	49
4.5	49	49	49	49	49	49	49	49	49	49
4.6	49	50	50	50	50	50	50	50	50	50
4.7	50	50	50	50	50	50	50	50	50	50
4.8	50	50	50	50	50	50	50	51	51	51
4.9	51	51	51	51	51	51	51	51	51	51
5.0	51	51	51	51	51	51	51	51	51	51
5.1	51	51	52	52	52	52	52	52	52	52
5.2	52	52	52	52	52	52	52	52	52	52
5.3	52	52	52	52	52	52	52	53	53	53
5.4	53	53	53	53	53	53	53	53	53	53
5.5	53	53	53	53	53	53	53	53	53	53
5.6	53	53	54	54	54	54	54	54	54	54
5.7	54	54	54	54	54	54	54	54	54	54
5.8	54	54	54	54	54	54	54	55	55	55
5.9	55	55	55	55	55	55	55	55	55	55
6.0	55	55	55	55	55	55	55	55	55	55
6.1	55	55	55	56	56	56	56	56	56	56
6.2	56	56	56	56	56	56	56	56	56	56
6.3	56	56	56	56	56	56	56	57	57	57
6.4	57	57	57	57	57	57	57	57	57	57
6.5	57	57	57	57	57	57	57	57	57	57
6.6	57	57	58	58	58	58	58	58	58	58
6.7	58	58	58	58	58	58	58	58	58	58
6.8	58	58	58	58	58	58	58	58	59	59
6.9	59	59	59	59	59	59	59	59	59	59
7.0	59	59	59	59	59	59	59	59	59	59
7.1	59	59	59	59	59	59	59	59	60	60
7.2	60	60	60	60	60	60	60	60	60	60
7.3	60	60	60	60	60	60	60	60	60	60
7.4	60	60	60	60	60	60	60	60	60	60
7.5	60	60	60	61	61	61	61	61	61	61
7.6	61	61	61	61	61	61	61	61	61	61
7.7	61	61	62	62	63	63	64	64	65	65
7.8	65	66	66	67	67	68	68	69	69	70
7.9	70	71	71	72	72	73	73	73	74	74

[illegible]

Discharge Rating Table - table values in CFS					
--	--	--	--	--	--

Rating assumes gated outlets are open and ungated outlet is open as of March 2021.		
--	--	--

[illegible]

White Tank FRS #4										
Discharge Rating Table - table values in CFS										
Rating assumes gated outlets are open and ungated outlet is open as of March 2021.										
	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
12.5	231	231	231	231	231	231	231	231	231	231
12.6	231	232	232	232	232	232	232	232	232	232
12.7	232	232	233	233	233	233	233	233	233	233
12.8	233	233	233	233	234	234	234	234	234	234
12.9	234	234	234	234	234	235	235	235	235	235
13.0	235	235	235	235	235	235	236	236	236	236
13.1	236	236	236	236	236	236	236	237	237	237
13.2	237	237	237	237	237	237	237	237	238	238
13.3	238	238	238	238	238	238	238	238	238	239
13.4	239	239	239	239	239	239	239	239	239	239
13.5	240	240	240	240	240	240	240	240	240	240
13.6	240	241	241	241	241	241	241	241	241	241
13.7	241	241	242	242	242	242	242	242	242	242
13.8	242	242	242	242	243	243	243	243	243	243
13.9	243	243	243	243	243	244	244	244	244	244
14.0	244	244	244	244	244	244	244	245	245	245
14.1	245	245	245	245	245	245	245	245	245	246
14.2	246	246	246	246	246	246	246	246	246	246
14.3	246	247	247	247	247	247	247	247	247	247
14.4	247	247	247	247	248	248	248	248	248	248
14.5	248	248	248	248	248	248	249	249	249	249
14.6	249	249	249	249	249	249	249	249	249	250
14.7	250	250	250	250	250	250	250	250	250	250
14.8	250	251	251	251	251	251	251	251	251	251
14.9	251	251	251	251	252	252	252	252	252	252
15.0	252	252	252	252	252	252	253	253	253	253
15.1	253	253	253	253	253	253	253	254	254	254
15.2	254	254	254	254	254	254	254	254	255	255
15.3	255	255	255	255	255	255	255	255	255	256
15.4	256	256	256	256	256	256	256	256	256	256
15.5	257	257	257	257	257	257	257	257	257	257
15.6	257	258	258	258	258	258	258	258	258	258
15.7	258	258	259	259	259	259	259	259	259	259
15.8	259	259	259	259	260	260	260	260	260	260
15.9	260	260	260	260	260	261	261	261	261	261
16.0	261	261	261	261	261	261	261	262	262	262
16.1	262	262	262	262	262	262	262	262	262	263
16.2	263	263	263	263	263	263	263	263	263	263
16.3	263	264	264	264	264	264	264	264	264	264
16.4	264	264	264	264	265	265	265	265	265	265
16.5	265	265	265	265	265	265	266	266	266	266
16.6	266	266	266	266	266	266	266	266	266	267
16.7	267	267	267	267	267	267	267	267	267	267
16.8	267	267	268	268	268	268	268	268	268	268
16.9	268	268	268	268	269	269	269	269	269	269

White Tank FRS #4										
Discharge Rating Table - table values in CFS										
Rating assumes gated outlets are open and ungated outlet is open as of March 2021.										
	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
17.0	269	269	269	269	269	269	269	270	270	270
17.1	270	270	270	270	270	270	270	270	270	271
17.2	271	271	271	271	271	271	271	271	271	271
17.3	271	272	272	272	272	272	272	272	272	272
17.4	272	272	272	272	273	273	273	273	273	273
17.5	273	273	273	273	273	273	274	274	274	274
17.6	274	274	274	274	274	274	274	274	274	275
17.7	275	275	275	275	275	275	275	275	275	275
17.8	275	275	276	276	276	276	276	276	276	276
17.9	276	276	276	276	277	277	277	277	277	277
18.0	277	277	277	277	277	277	277	278	278	278
18.1	278	278	278	278	278	278	278	278	278	279
18.2	279	279	279	279	279	279	279	279	279	279
18.3	279	280	280	280	280	280	280	280	280	280
18.4	280	280	280	280	281	281	281	281	281	281
18.5	281	281	281	281	281	281	282	282	282	282
18.6	282	282	282	282	282	282	282	282	282	283
18.7	283	283	283	283	283	283	283	283	283	283
18.8	283	283	284	284	284	284	284	284	284	284
18.9	284	284	284	284	285	285	285	285	285	285
19.0	285	285	285	285	285	285	285	286	286	286
19.1	286	286	286	286	286	286	286	286	286	287
19.2	287	287	287	287	287	287	287	287	287	287
19.3	287	288	288	288	288	288	288	288	288	288
19.4	288	288	288	288	289	289	289	289	289	289
19.5	289	289	289	289	289	289	290	290	290	290
19.6	290	290	290	290	290	290	290	290	290	291
19.7	291	291	291	291	291	291	291	291	291	291
19.8	291	291	292	292	292	292	292	292	292	292
19.9	292	292	292	292	293	293	293	293	293	293
20.0	293	293	293	293	293	293	293	293	294	294
20.1	294	294	294	294	294	294	294	294	294	294
20.2	294	294	295	295	295	295	295	295	295	295
20.3	295	295	295	295	295	295	296	296	296	296
20.4	296	296	296	296	296	296	296	296	296	296
20.5	297	297	297	297	297	297	297	297	297	297
20.6	297	297	297	297	298	298	298	298	298	298
20.7	298	298	298	298	298	298	298	298	298	299
20.8	299	299	299	299	299	299	299	299	299	299
20.9	299	299	299	300	300	300	300	300	300	300
21.0	300	300	300	300	300	300	300	301	301	301
21.1	301	301	301	301	301	301	301	301	301	302
21.2	302	302	302	302	302	302	302	302	302	302
21.3	302	302	303	303	303	303	303	303	303	303
21.4	303	303	303	303	304	304	304	304	304	304

White Tank FRS #4										
Discharge Rating Table - table values in CFS										
Rating assumes gated outlets are open and ungated outlet is open as of March 2021.										
	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
21.5	304	304	304	304	304	304	304	305	305	305
21.6	305	305	305	305	305	305	305	305	305	306
21.7	306	306	306	306	306	306	306	306	306	306
21.8	306	306	307	307	307	307	307	307	307	307
21.9	307	307	307	307	308	308	308	308	308	308
22.0	308	308	308	308	308	308	308	308	309	309
22.1	309	309	309	309	309	309	309	309	309	309
22.2	309	309	310	310	310	310	310	310	310	310
22.3	310	310	310	310	310	310	311	311	311	311
22.4	311	311	311	311	311	311	311	311	311	311
22.5	312	312	312	312	312	312	312	312	312	312
22.6	312	312	312	312	312	313	313	313	313	313
22.7	313	313	313	313	313	313	313	313	313	314
22.8	314	314	314	314	314	314	314	314	314	314
22.9	314	314	314	315	315	315	315	315	315	315
23.0	315	321	327	333	339	345	352	358	365	372
23.1	379	386	393	400	407	415	423	430	438	447
23.2	455	463	472	480	489	498	507	517	526	536
23.3	546	556	566	576	587	598	609	620	631	643
23.4	654	666	679	691	704	716	730	743	756	770
23.5	784	798	813	828	843	858	874	890	906	922
23.6	939	956	973	991	1009	1027	1046	1065	1084	1103
23.7	1123	1144	1164	1185	1207	1228	1250	1273	1296	1319
23.8	1343	1367	1392	1417	1442	1468	1494	1521	1548	1576
23.9	1604	1633	1662	1692	1722	1753	1784	1816	1848	1881
24.0	1915	1934	1954	1973	1993	2013	2033	2053	2074	2095
24.1	2115	2137	2158	2179	2201	2223	2245	2268	2290	2313
24.2	2336	2359	2383	2406	2430	2454	2479	2503	2528	2553
24.3	2578	2604	2630	2656	2682	2709	2735	2762	2790	2817
24.4	2845	2873	2901	2930	2959	2988	3017	3047	3077	3107
24.5	3138	3168	3200	3231	3263	3295	3327	3360	3392	3426
24.6	3459	3493	3527	3562	3596	3632	3667	3703	3739	3775
24.7	3812	3849	3887	3925	3963	4001	4040	4079	4119	4159
24.8	4199	4240	4281	4323	4365	4407	4450	4493	4536	4580
24.9	4624	4669	4714	4759	4805	4852	4899	4946	4993	5041
25.0	5090	5122	5154	5186	5218	5250	5283	5316	5349	5382
25.1	5416	5449	5483	5517	5551	5585	5620	5655	5690	5725
25.2	5760	5796	5832	5868	5904	5941	5977	6014	6051	6088
25.3	6126	6164	6201	6240	6278	6317	6355	6394	6434	6473
25.4	6513	6553	6593	6633	6674	6715	6756	6797	6839	6881
25.5	6923	6965	7007	7050	7093	7136	7180	7224	7268	7312
25.6	7356	7401	7446	7491	7537	7583	7629	7675	7722	7768
25.7	7816	7863	7911	7958	8007	8055	8104	8153	8202	8252
25.8	8301	8351	8402	8453	8504	8555	8606	8658	8710	8763
25.9	8815	8868	8922	8975	9029	9083	9138	9193	9248	9303

White Tank FRS #4										
Discharge Rating Table - table values in CFS										
Rating assumes gated outlets are open and ungated outlet is open as of March 2021.										
	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
26.0	9359	9405	9452	9499	9546	9593	9641	9688	9736	9785
26.1	9833	9881	9930	9979	10029	10078	10128	10178	10228	10278
26.2	10329	10380	10431	10482	10534	10585	10637	10690	10742	10795
26.3	10848	10901	10954	11008	11062	11116	11171	11225	11280	11335
26.4	11391	11446	11502	11558	11615	11671	11728	11785	11843	11900
26.5	11958	12017	12075	12134	12193	12252	12312	12371	12431	12492
26.6	12552	12613	12674	12736	12797	12859	12921	12984	13047	13110
26.7	13173	13237	13301	13365	13429	13494	13559	13625	13690	13756
26.8	13822	13889	13956	14023	14090	14158	14226	14294	14363	14432
26.9	14501	14570	14640	14710	14781	14852	14923	14994	15066	15138
27.0	15210	15261	15312	15363	15414	15466	15517	15569	15621	15673
27.1	15725	15778	15830	15883	15936	15989	16042	16095	16148	16202
27.2	16256	16310	16364	16418	16473	16527	16582	16637	16692	16747
27.3	16802	16858	16914	16969	17026	17082	17138	17195	17251	17308
27.4	17365	17422	17480	17537	17595	17653	17711	17769	17827	17886
27.5	17945	18004	18063	18122	18181	18241	18301	18360	18421	18481
27.6	18541	18602	18663	18724	18785	18846	18908	18969	19031	19093
27.7	19155	19218	19280	19343	19406	19469	19533	19596	19660	19724
27.8	19788	19852	19916	19981	20046	20111	20176	20241	20307	20372
27.9	20438	20504	20571	20637	20704	20771	20838	20905	20973	21040
28.0	21108	21167	21226	21284	21344	21403	21462	21522	21582	21641
28.1	21701	21761	21822	21882	21943	22003	22064	22125	22186	22248
28.2	22309	22371	22432	22494	22556	22619	22681	22743	22806	22869
28.3	22932	22995	23058	23121	23185	23249	23312	23376	23441	23505
28.4	23569	23634	23699	23764	23829	23894	23959	24025	24091	24156
28.5	24222	24289	24355	24421	24488	24555	24622	24689	24756	24824
28.6	24891	24959	25027	25095	25163	25232	25300	25369	25438	25507
28.7	25576	25645	25715	25785	25855	25925	25995	26065	26136	26206
28.8	26277	26348	26419	26491	26562	26634	26706	26778	26850	26923
28.9	26995	27068	27141	27214	27287	27360	27434	27508	27582	27656
29.0	27730									
	Rating #4, NS Table #957									
	Effective Date: 03/01/2021									
	Update: 05/20/2021									